

RECEIVED

Health & Community Services

APR 06 2023

# San Juan County



HCS

P.O. Box 607 • 145 Rhone, Friday Harbor, WA 98250

Phone: (360) 378-4474 • Fax: (360) 378-7036

RECEIVED  
700  
4/11/23

S.J.C. DEPARTMENT OF

APR 07 2023

COMMUNITY DEVELOPMENT

## SEWAGE DESIGN APPLICATION

Design No: 23-0046

This application is to be used for any activity requiring a Sewage Design per SJCC 8.16. When numbered, signed, and dated, this becomes a Sewage Design. Please fill out the form completely, or it will not be accepted. Sewage Designs are valid for five years from the date of issuance. Applicant may appeal any decision pertinent to this design with the San Juan Co. Health Officer. An approved design is required before the issuance of a new installation permit.

### PROPERTY INFORMATION:

Tax Parcel Number: 171714010000 Property Size (acres/square feet): 5.54 acres Island: Orcas

Property Address/ Directions to Property: Atticus Lane

### APPLICANT INFORMATION:

Name of Applicant(s): KURT HUNT Email: \_\_\_\_\_

Telephone: \_\_\_\_\_

#### Application Type (✓ one)

- New Residential
- New Non-residential/Commercial
- Revision
- \*Original Design #: \_\_\_\_\_
- Connection to Community System
- \*System Name: \_\_\_\_\_

#### Water Supply (✓ one)

- Individual Well (serves up to 2 parcels)
- Community Water Supply
- \*Water System Name: \_\_\_\_\_
- Other (specify): \_\_\_\_\_

#### Proposed System Type (✓ one)

- Gravity Distribution
- Pressure Distribution
- Mound
- Sand Filter
- Other (specify): \_\_\_\_\_

Proposed Number of Bedrooms: 3

I hereby certify that I have read and examined this application and know the same to be true and correct. All provisions or laws and ordinances governing this project will be complied with whether specified herein or not. I understand that the granting of this design does not presume to give authority to violate or cancel provisions of any other state or local law regulating construction or land or shoreline use.

Agent for Kurt Hunt  
Signature of Applicant

5 Mar 2023  
Date

Note: Designers must either stamp design with an approved valid seal or attach a copy of their state designer license to each design. Designers may file their state license with the department instead of attaching a copy to each design.



### FOR OFFICIAL USE ONLY

### CONDITIONS FOR APPROVAL:

#### DCD Comments:

- 1. If during the excavation or development of the site, any area of potential archaeological significance is uncovered, all activity in the immediate vicinity of the find must be halted immediately and the county's inadvertent discovery plan must be followed.
- 2. Certification of compliance with Stormwater Best Management Practice: Minimum Requirements 1-12 is a condition of approval
- 3. See attached conditions

#### H&CS Comments:

- 1. The attached environmental health covenant needs to be recorded prior to the issuance of the installation permit.
- 2. A signed proprietary service agreement needs to be submitted prior to the issuance of the installation permit.
- 3. Written verification from the O&M provider that they will complete four (4) complementary semi-annual inspections in the first two (2) years of use, needs to be submitted prior to the issuance of the installation permit.
- 4. The attached Class A Waiver mitigation measures must be followed by the installer and verified by the Designer.
- 5. If the installed curtain drain fails to lower the water table, the owner is required to install a system that meets DOH's vertical separation requirements (curtain drain shall be monitored by the Designer in Jan. & Mar. in the 1st & 2nd years after installation to determine if it is working).

DCD Review: [Signature]

Date: 6/1/2023

Design Approved: [Signature]

Date: 06/29/23